



- GENERAL NOTES:**
- A. IN EG LAB 112 AND SHOP AREA 110 EQUIPMENT AND CIRCUITING SHALL BE POWER LIMITED TO COMPLY WITH CLASS 1, DIVISION 1 HAZARDOUS ENVIRONMENT REQUIREMENTS.
- KEYED NOTES:**
1. PA/SECURITY WALL MOUNTED RACK. RE: "WALL MOUNTED RACK DETAIL," C/E-801.


REES ASSOCIATES INC
ARCHITECTURE PLANNING INTERIORS
REES PLAZA AT EAST WHARF
9211 LAKE HEFNER PARKWAY, SUITE 300
OKLAHOMA CITY, OKLAHOMA 73120
P: 405.942.7337 F: 405.948.1261

Mechanical Engineer
050 Engineering Company
228 Robert S. Kerr Ave, Suite 515
Oklahoma City, OK 73102
P: 405.236.2030 F: 405.239.6101

Electrical Engineer
Horner Associates Engineers, Inc.
1306 Commerce Drive
Norman, OK 73071
P: 405.801.2528 F: 405.801.2529

Civil Engineer
MacArthur Associated Consultants
3033 NW 63rd St., Ste. 250E
Oklahoma City, OK 73116
P: 405.848.2471 F: 405.848.2474

Structural Engineer
Zahl-Ford, Inc.
8411 S. Walker
Oklahoma City, OK 73139
P: 405.634.3393 F: 405.634.6414



H-A-E Horner Associates Engineers, Inc.
1306 Commerce Dr., Norman, OK 73071
Certificate of Registration No. 013520, Expires 6/30/2011
info@hoeinc.com P: (405) 801-2528 F: (405) 801-2529

100% SUBMITTAL				
REV	DATE	DESCRIPTION	CHECK	APP'D
DEPARTMENT OF TRANSPORTATION FEDERAL AVIATION ADMINISTRATION MIKE MONRONEY AERONAUTICAL CENTER - OKLAHOMA CITY, OKLAHOMA PSL - POWER SERVICES LABORATORY				
PUBLIC ADDRESS PLAN Construction Work Request No: 09-018745				
PREPARED BY Rees Associates		APPROVED BY Jon Berkman		
DESIGNED JGH	ISSUED BY OFFICE OF FACILITY MANAGEMENT	DATE May 26, 2011	E-802	
DRAWN BLP	WORK ORDER NO. 09-018745	DRAWING NO. 08-008257	26 of 31	